

DEPARTMENT OF THE ARMY
Omaha District, Corps of Engineers
106 South 15th Street
Omaha, Nebraska 68102-1618

:NOTICE: Failure to acknowledge : Solicitation No. DACA45 03 R 0018
:all amendments may cause rejec- :
:tion of the offer. See FAR : Date of Issue: 21 JAN 2003
:52.215-1 of Section 00100 : Date of Receiving Proposals:
25 FEB 2003

Amendment No. 0003
11 February 2003

SUBJECT: Amendment No. 0003 to specification and drawings for Construction of
**ADAL SBIRS MISSION CONTROL STATION (MCS), CRWU 03-3001, BUCKLEY AFB,
COLORADO.**

Solicitation No. DACA45 03 R 0018.

TO: Prospective Offerors and Others Concerned

1. The specifications and drawings for subject project are hereby modified as follows (revise all specification indices, attachment lists, and drawing indices accordingly).

a. Specifications. (Descriptive Changes.)

(1) Amendment No. 0002, Page 4, Item 1.b (1) (b) concerning Sheet C2.01 of drawings, revise sub-item (b) to read:

'(b) North of NEW SBIRS MCS ADDITION, delete invert elevations reading "I.E. 1684.603" and "I.E. 1684.626" and substitute "I.E. 1684.753" and "I.E. 1684.776", respectively.'

(2) Standard Form SF 1442, Page 00010-3, delete this page in its entirety and substitute attached Page 00010-3. Option Item O-2, "carpet tiles" was replaced with "broadloom carpet".

(3) Section 00110, Page 11, paragraph 6.5.1.2, item a. Development of Percentage Floors, line 12, delete "Severely Disabled" and substitute "Service-Disabled".

(4) Section 09915, Page 3, paragraph 2.2.3, item a. Carpet, lines 2 and 3, delete "Also located in existing corridors 210 and 330.)" and substitute:

"Replace existing as required in existing corridors 210 and 330, see drawings. Option O-2 includes new carpet in corridors 060, 210, 240 and 330."

b. Drawings (Not Reissued). The following sheets of drawing code AF 610-90-06 are revised as indicated below with latest revision date of 11 February 2003. These drawings are not reissued with this amendment.

(1) Sheet A5.20, CMU Wall Type 12, note description reading "STC

58 1 HR. WITH ... INSULATION WHERE INDICATED", delete "SAND-FILLED CMU CORES" and substitute:

"CMU WITH ALL CELLS GROUTED FULL".

(2) Sheet A6.01, GENERAL NOTES, note 21, line 1, delete "REINSTALL CARPET SALVAGED FROM THIS AREA."

(3) Sheet A9.06,

(a) DETAILS 8 & 9, note reading "150mm STELL TUBE COLUMN EXTENDING FROM CONCRETE ... FOR FRAMING", delete "*SEE STRUCT. DWGS FOR FRAMING" and substitute "SEE ELEV 3/S6.3 FOR FRAMING" (for each detail).

(b) Right hand side of sheet, add the following General Notes:

"GENERAL NOTES:

1. FOR DETAILS 1 THROUGH 5, METAL ROOF DECK FLUTES TO RUN PERPENDICULAR OR PARALLEL TO WALLS, SEE STRUCTURAL DRAWINGS FOR DIRECTION OF ROOF DECK FLUTES."

(4) Sheet S4.1, DATA CHASE #3A SOUTH WALL LOOKING NORTH, Move elevation line "-2880" from bottom horizontal line of Data Chase Elevation up to next horizontal line. (Elevation line -2880 should be at the top of the Data Chase slab instead of at the bottom.)

(5) Sheet S7.1, PRECAST CONCRETE PANEL SCHEDULE, add the following row for 4 new precast panels:

"L | 4 @ 4000 | A | 1"

(6) Sheet E4.01, NOTES, delete Note 6 in its entirety and substitute:

"6. NEW #2/0 A.W.G. BARE COPPER DOWN CONDUCTOR IN 42 mm PVC CONDUIT. BOND DOWN CONDUTOR TO 150 mm PIPE (DETAIL 5, SHEET A9.02) AT BOTH ENDS."

(7) Sheet E7.03, Details 1 thru 4, lower right hand corner of each detail, note reading "PROVIDE CABLE TRAY SUPPORTS @ 2400mm OC MAX", delete "2400mm OC MAX" and substitute "1800mm OC MAX" (each detail).

c. Drawings (Reissued). The following sheets of drawing code AF 610-90-06 are revised with latest revision date of 11 February 2003, and reissued with this amendment. (Revisions are included on web site <http://ebs-nwo.wes.army.mil/>).

(1) Sheets A1.02, A6.03, and A7.01.

(2) Sheets S0.1, S0.3, and S6.3.

2. This amendment is a part of the proposing papers and its receipt shall be acknowledged on the Standard Form 1442. All other conditions and requirements of the specifications remain unchanged. If the proposals have been mailed prior to receiving this amendment, you will notify the office where proposals are received, in the specified manner, immediately of its receipt and of any changes in your proposal occasioned thereby.

a. Hand-Carried Proposals shall be delivered to the U.S. Army Corps of Engineers, Omaha District, Contracting Division (Room 301), 106 South 15th Street, Omaha, Nebraska 68102-1618.

b. Mailed Proposals shall be addressed as noted in Item 8 on Page 00010-1 of Standard Form 1442.

3. Offers will be received until 2:00 p.m., local time at place of receiving proposals, 25 FEB 2003.

Attachments:

Standard Form SF1442, Page 00010-3 (Pricing Schedule)
Dwgs. listed in l.c. above

U.S. Army Engineer District, Omaha
Corps of Engineers
106 South 15th Street
Omaha, Nebraska 68102-1618

11 February 2003
DRL/4547

PRICING SCHEDULE

<u>Item No.</u>	<u>Description</u>	<u>Quantity</u>	<u>Unit</u>	<u>Amount</u>
<u>BASIC ITEMS</u>				
1.	All Work Complete for the ADAL SBIRS Mission Control Station, excluding Options listed below.	Job	L.S.	\$ _____

OPTION ITEMS

O-1	All work complete for brushed stainless steel perforated metal panels above alcove entrance doors.	Job	L.S.	\$ _____
O-2	All work complete to replace broadloom Carpet In the identified existing MCS corridors.	Job	L.S.	\$ _____
O-3	All work complete for cable trays in the new data chase extension.	Job	L.S.	\$ _____
O-4	All work complete for the alterations in the existing LARC area.	Job	L.S.	\$ _____

TOTAL AMOUNT (BASIC ITEMS & ALL OPTIONS) \$ _____

NOTES:

1. See Section 00100, INSTRUCTIONS, CONDITIONS AND NOTICES OFFERORS, paragraph EVALUATION OF OPTIONS for evaluation of pricing items and options. The Government reserves the right to exercise Options within 90 calendar days after Notice to Proceed (NTP).
2. Prices must be entered for all line items on the Pricing Schedule. Total amount prices submitted without prices for individual line items will not be evaluated. Additions will be subject to verification by the Government. In case of variation between the lump-sum prices and the total amount, the lump-sum prices will be considered the price. In case of variation between the unit prices and the extensions, the unit prices will be considered the amount proposed.
3. Modification to the Pricing Schedule items, basic or options should state the application of the adjustment to each respective lump sum (LS) price affected. If the modification is not so apportioned, the single adjustment will apply to Basic Item No. 1.